



ATBILSTĪBAS SERTIFIKĀTS

Certification Centre, Latvian Academy of Sciences,
1 Akademijas laukums, Riga, Republic of Latvia, phone/ fax: +371 67212807,
E-mail: certcn@latnet.lv ; www.sertifikacijacentrs.lv

Construction product conformity certificate No. 0000825

It has been stated that the construction product

**Fire resistant wooden single and double doorsets
with glazing (type 21940) without glazing (type 21901)
finished with veneer (stained, varnished), painted or with plastic coating,
fire resistance class EW 30-C0 / EI₁ 30-C0 / EI₂ 30-C0 / E 30-C0**
is produced by the manufacturer

Reaton Ltd,

with the head office Ciekurkalna 2 linija 74, LV 1006, Riga, Republic of Latvia,
production site 20 Krustabaznicas street, LV-1006, Riga, Republic of Latvia,

is submitted to the initial type-testing of the product and initial inspection of the factory and the factory production control with further continuous surveillance, assessment and approval of the factory production control. The assessment is carried out by Certification Centre of Latvian Academy of Sciences and assessment results attest that requirements of the standard

EN 13501-2:2016,

are fulfilled.

This certificate was issued on 29 March 2018 and remains valid as long as the conditions laid down in the standard in reference or the manufacturing conditions in the factory, or factory production control, or the product itself are not modified significantly. The certificate was issued at non-regulated area with validity latest on 21 April 2021.

Riga,
29 March 2018



J. Matiss
Chairman of the Board,
Certification Centre Latvian Academy of Sciences
Dr. Habil. Eng.



Appendix to the Product Conformity Certificate No. 0000825.

Certification has been carried out at non-regulated area according to the System 1, which comprises initial tests of the product, initial inspection of the factory and factory production control (FPC), continuous surveillance, assessment and approval of the FPC.

Fire resistance classification report No 59-36.2017.1 of 21.12.2017; Extended application test report No 59-13.2017.2 of 20.12.2017 issued by Fire and rescue department of the Republic of Lithuania, Fire Research Centre, Švitrigailos str. 18, LT-03223 Vilnius, Lithuania, e-mail: gtc@vpgt.lt www.gtcentras.lt.

SIA "Reatorn"